

## TOWN OF BAY HARBOR ISLANDS CCR 2015 REPORT

PARAMETER	FEDERAL GOAL MCL	FEDERAL/STATE MCL	BAY HARBOR ISLANDS RESULTS	YEAR TESTED	MCL VIOLATION	MAJOR SOURCES
<b>INORGANIC COMPOUNDS</b>						
Lead	0 ppm	AL=15 ppb or 0.015 mg/L	1 out of 30 homes exceeded AL (3.3%)	2014	NO	Corrosion of Household Plumbing
Copper	1.3 ppm or 1300 ppb or 1.3 mg/L	AL=1300 ppb or 1.3 mg/L	0 out of 30 (0%)	2014	NO	Corrosion of Household Plumbing
<b>STAGE 2 (DBPD)</b>						
Haloacetic Acids (ppb)	60 ppb	60 ppb	53.93 ppb	2015	NO	By Product of Drinking Water Disinfection
Total Trihalomethanes (ppb)	80 ppb	80 ppb	30.57 ppb	2015	NO	By Product of Drinking Water Disinfection
<b>MICRO. CONTAMINANTS</b>						
Total Coliform bacteria	0.00%	0%	0% (0 of 96)	2015	NO	Florida Department of Health